



切妻屋根面（片面解放型建屋）に於ける風圧係数

建物面を押す方向を正（+）とする							
勾配		Cpi=0 の値		風 上	風 下	風 上	風 下
X / 1 0	角度	正の係数	負の係数				
1 . 0	5.71		-1.0	-1.6	-1.1	-0.60	-0.1
1 . 5	8.53		-1.0	-1.6		-0.60	
2 . 0	11.31	0.01	-0.95	-1.55		-0.55(+0.41)	
2 . 5	14.04	0.04	-0.86	-1.46		-0.46(+0.44)	
3 . 0	16.70	0.07	-0.77	-1.37		+0.47(-0.37)	
3 . 5	19.29	0.09	-0.67	-1.27		+0.49(-0.27)	
4 . 0	21.80	0.12	-0.59	-1.19		+0.52(-0.19)	
4 . 5	24.23	0.14	-0.50	-1.10		+0.54(-0.10)	
5 . 0	26.57	0.17	-0.40	-1.00		0.57	
6 . 0	30.96	0.21	-0.28	-0.88		0.61	
7 . 0	34.99	0.27	-0.20	-0.80		0.67	
8 . 0	38.66	0.32	-0.10	-0.70		0.72	
9 . 0	41.99	0.36	-0.06	-0.66		0.76	
1 0 . 0	45.00	0.40	0	-0.60		0.80	