



切妻屋根面（閉鎖型建屋）に於ける風圧係数

建物面を押す方向を正（＋）とする						風上採用値		風下採用値		小屋
勾配		Cpi=0		Cpi=-0.2		最大値		Cpi=0	Cpi=-0.2	→ 合計
X／１０	角度	正の係数	負の係数	正の係数	負の係数	＋	－			
１．０	５.７１		-１.０		-０.８		-１.０	-０.５	-０.３	０.５０
１．５	８.５３		-１.０		-０.８		-１.０			０.５０
２．０	１１.３１	０.０１	-０.９５	０.２１	-０.７５	０.２１	-０.９５			０.５１
２．５	１４.０４	０.０４	-０.８６	０.２４	-０.６６	０.２４	-０.８６			０.５４
３．０	１６.７０	０.０７	-０.７７	０.２７	-０.５７	０.２７	-０.７７			０.５７
３．５	１９.２９	０.０９	-０.６７	０.２９	-０.４７	０.２９	-０.６７			０.５９
４．０	２１.８０	０.１２	-０.５９	０.３２	-０.３９	０.３２	-０.５９			０.６２
４．５	２４.２３	０.１４	-０.５０	０.３４	-０.３０	０.３４	-０.５０			０.６４
５．０	２６.５７	０.１７	-０.４０	０.３７	-０.２２	０.３７	-０.４０			０.６７
６．０	３０.９６	０.２１	-０.２８	０.４１	-０.０８	０.４１	-０.２８			０.７１
７．０	３４.９９	０.２７	-０.２０	０.４７	０	０.４７	-０.２０			０.７２
８．０	３８.６６	０.３２	-０.１０	０.５２	０.０７	０.５２	-０.１０			０.８２
９．０	４１.９９	０.３６	-０.０６	０.５６	０.１４	０.５６	-０.０６			０.８６
１０．０	４５.００	０.４０	０	０.６０	０.２０	０.６０	０			０.９０

■ 小屋合計とは左右の水平分力の合計値（木造計算用）

Lion